

Report on Surface Moisture of Blocks

Page 1 of 1

ACES Client	ESPAC -Precast Aerated Concrete	Report No.	KMR16000655
Sample No.	KMS16000182	Date Reported	21-03-16
Request No.	KMQ16000141	Sample No.	KMS16000182
Project Name	Autoclaved Aerated Concrete Products testing		
Test Method	ASTM 796	Test Date	14-03-16
Notes	-	Tested By	Wassel

Sr No	Time	Moisture Penetration Depth
1	72 hr	2mm



Rashad A. Al Kilani
 Branch Manager
 Arab Company for Laboratories & Soil (ACES)

ACES
 Arab Company الشركة العربية
 For Laboratories & Soil للمختبرات و التربة
 Special For Reports خاص بالتقارير
 Khobar Branch فروع الخببر

ACES Khobar: P.O.Box 70156 Al-Khobar 31952 - Tel:+966 (13) 881 1941 / 881 1942 - Fax:+966 (13) 881 1947 - C.C. No. 98216 - C.R. : 2051037267 - E-mail: aceskhobar@aces-int.com
 ACES Riyadh: P.O.Box 46891 Riyadh 11542 - Tel:+966 (11) 237 2222 / 235 3467 - Fax:+966 (11) 235 7434 - C.C. No.116998- C.R. : 1010172258 - E-mail: acesriyadh@aces-int.com
 ACES Jeddah: P.O.Box 132905 Jeddah 21382 - Tel:+966 (12) 664 1422, 663 6380 - Fax:+966 (12) 663 5448 - C.C. No. 106934 - C.R. : 4030147586 - E-mail: acesjeddah@aces-int.com
 ACES Najran: P.O.Box 406 Najran - Tel:+966 (17) 523 9037 / 523 0273- Fax:+966 (17) 523 5761 - C.C. No. 1117678 - C.R. : 5950017513 - E-mail: acesnajran@aces-int.com
 ACES Buraydah: P.O.Box 52391 Buraydah 8225 - Tel.:+966 (16) 384 4575 - Fax:+966 (16) 384 4001 - C.C. No. 601001156942 - C.R. : 1131032563 - E-mail: acesburaydah@aces-int.com

Website : www.aces-int.com



شركة ذات مسؤولية محدودة رأس المال ٣,٠٠٠,٠٠٠